

# South Coast Air Quality Management District

## Facility Equipment List Report

Facility: 138823 MAERSK DISTRIBUTION SERVICES INC MR: Contact: LEWIS FAKKAS Jr. (323) 5682603  
Last Inspection: 08/21/2012 TS: TS-11 Industrial: Sector-based Ins Quarter: 0010 - inspect in 3rd quarter, every year  
SIC: Facility Status: Active On Hold: N Suspended: N  
Inspector: LB02 LALO A. BAKHOUM Assignment No. 800927 Facility Team: J  
Inspection Date: 12/18/2003 Disposition: Notice Of Violation  
Location Address: 5011 FIRESTONE PL, SOUTH GATE 90280-3533 Sector:LC  
Mailing Address: 5011 FIRESTONE PL, SOUTH GATE 90280-3533 Sector:LC  
Instruction:

RECLAIM: N		TITLE V: N		SIP:		AIR:	
Application No.	Permit No.	Permit Issue Date	Permit Status	Equipment Category	BCAT/CCAT Description	Application Date	Application Status
426851	F76105	06/16/2005	ACTIVE	043901 BCAT	I C E (50-500 HP) EM ELEC GEN-DIESEL	03/09/2004	PERMIT TO OPERATE GRANTED

Report: On December 11, 03 at 08:25 hrs I arrived at the above-mentioned location, pursuant to compliant inspection. I met with Mr. Lewis Farkas, facility manager. Hudd distribution services, Inc., is one of the largest warehouse/storage, distribution services for Wall- Mart, Sears and other department stores. Mr. Farkas discussed facility operations and conducts the tour. During my inspection I observed an internal combustion engine (ICE); Perkins, serial number YB50604U708557D, diesel-fired, which powered an emergency generator. I asked Mr. Farkas if this equipment being used. He replied "Yes". I also met with David maintenance services man who had provided the services/tests for the ICE, and I inquired about the maximum brake horse power of the ICE. Mr. David, tried to find the information on the ICE, however he couldn't. I issued NC # C 87573, directing facility to; provide information regarding the maximum horsepower of the ICE. Mr. Farkas stated that he had to call the manufacture to request that information. On December 17, 2003 2:31 PM, I received an e-mail from Mr. Lewis Farkas, regarding follow-up on Notice to Comply # C 87573. The E-mail states "The back-up generator we looked at last Thursday is 151 hp. It was installed in 1999 and has 20.7 hours, Started only for testing. It has been used several times for short periods. Our Safety and Compliance Manager has been in touch with the AQMD about a permit status. Please advise what you may require". I called the AQMD customer services records for verification of permitting issues, I was informed that there was no record of application been submitted for the above mentioned ICE. On Dec. 18, 2003 I issued Notice of Violation No. P 42320 to the facility, pursuant to R201, 203(a); installing/operating one ICE; Perkins, serial number YB50604U708557D, diesel-fired, without permit from the AQMD. I also explained in details the provisions of District R201, and 203 (a).